



**GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**



From  
The District fire officer,  
  
Rangareddy Division.

To,  
K.T. MAHI,  
SY.NO. 22,  
23,  
25 & 26,  
WATER PIPE LINE ROAD,  
AZIZNAGAR VILLAGE,  
MOINABAD MANDAL,  
RANGA REDDY DISTRICT.,

Ack. No.422500002021 Dated:07/01/2022

Sir,  
Sub: TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT –Rangareddy Division. Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building of **SREENIDHI INTERNATIONAL SCHOOL (ACADEMIC BLOCK-1),SY.NO. 22,23,25 & 26, WATER PIPE LINE ROAD, AZIZNAGAR VILLAGE, MOINABAD MANDAL, RANGA REDDY DISTRICT. /-Aziznagar/Moinabad/Rangareddy , –** Regarding.



Ref: 1. Acknowledgement No **422500002021**  
2. This Office NOC for Occupancy Ack/RC No.**RC.NO. 1433/A1/2009** dt.07/01/2022  
3. Non Multi storeyed Building Inspection Committee Report.,  
Ack. No. **422500002021**, dt. **07/01/2022**

\*\*\*\*\* \*\*

1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of **SREENIDHI INTERNATIONAL SCHOOL (ACADEMIC BLOCK-1),SY.NO. 22,23,25 & 26, WATER PIPE LINE ROAD, AZIZNAGAR VILLAGE, MOINABAD MANDAL, RANGA REDDY DISTRICT. /-Aziznagar/Moinabad/Rangareddy**

2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with **1 Ground, 1 Floors**, with a height of **6.00** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy .

3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with **1 Ground, 1 Floors**, with a height of **6.00** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy

4) Open Spaces:The builder provided the following open spaces all around the building.

Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
a 1	North	6.00	6.00
2	South	6.00	6.00
3	East	6.00	6.00
4	West	6.00	6.00
b Sl. No	Gate Width As per Occupancy NOC	as per Noc occupancy	provided now
1	Entry gate width	4.50	7.0
2	Entry Gate Head Clearance	5.00	5.0
3	Exit Gate Width	4.50	7.0
4	Exit Gate Head Clearance	5.00	5.00

5) Travel Distance

For Sreenidhi International School

*(Handwritten signature)*

*mahe*  
Correspondent



Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point ( Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	30.00	29.95
2	The Dead end of the corridor length in exit access. ( 6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00	6.00

6) Stair Cases (As per Occupancy NOC) :

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
1	Internal staircases	1.50	1	Ground	1st Floor
2	External staircases	1.50	1	Ground	1st Floor

7) Means of Escape Floor Wise Details :

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per Occupancy NOC	Means escape available now
1	Ground	835.85	EDUCATIONAL B-1 Schools up to senior secondary level	209.00	4.18	5.00
2	1st Floor	473.00	EDUCATIONAL B-1 Schools up to senior secondary level	118.00	2.36	3.00

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Sl.no	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Fire Alarm System	Electronic Fire Alarm System	Automatic detection and alarm system
1	Ground	5.00	1.00	0.00	0.00	0.00	0.00
2	1st Floor	3.00	1.00	0.00	0.00	0.00	0.00

10) Fire Fighting Installations As per Occupancy NOC :

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	14	14
First Aid Hose Reel	2	2
Terrace Tank over Respective Tower Terrace in Litres	10000	10000
Pump Capacity in LPM at the Terrace Tank Level with Minimum Pressure of 3.5 kg/cm <sup>2</sup>	450	450

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measures and there is no deficiencies.

12. Remarks :

Based on the Recommendation of the Inspection Committee, the issuance of Renewal of NOC for Occupancy was approved.

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with **SREENIDHI INTERNATIONAL SCHOOL (ACADEMIC BLOCK-1),SY.NO. 22,23,25 & 26, WATER PIPE LINE ROAD, AZIZNAGAR VILLAGE, MOINABAD MANDAL, RANGA REDDY DISTRICT. /-**

**Aziznagar/Moinabad/Rangareddy**

with a height of **6.00** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy subject to the following conditions

Sl No	Builder and Management Body	Occupant	Management Body and fire and security personnel
1	-a) All the fire protection	All the escape/exit routes shall not be kept locked/blocked or	All the occupants must know the correct method of operation of the fire fighting

	arrangements shall be maintained in good condition as seen during inspection. -b) Do's and Don'ts in case of fire shall be prominently displayed in entire building	encroached	systems installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for Five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely,  
District fire officer,  
Rangareddy Division.

Copies to:

- i) The Management
- ii) Non Multi storeyed Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"

*Amph*

For Greenidhi International School

*mehle*

Correspondent





GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT



From  
The District fire officer,  
Rangareddy Division.

To,  
K.T. MAHI,  
SY.NO. 22,  
23,  
25 & 26,  
WATER PIPE LINE ROAD,  
AZIZNAGAR VILLAGE,  
MOINABAD MANDAL,  
RANGA REDDY DISTRICT.,

Ack. No.422530002021 Dated:07/01/2022

Sir,

Sub: TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT –Rangareddy Division. Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building of **SREENIDHI INTERNATIONAL SCHOOL (ACADEMIC BLOCK-2),SY.NO. 22,23,25 & 26, WATER PIPE LINE ROAD, AZIZNAGAR VILLAGE, MOINABAD MANDAL, RANGA REDDY DISTRICT. /-Aziznagar/Moinabad/Rangareddy , –** Regarding.



Ref:

1. Acknowledgement No 422530002021
2. This Office NOC for Occupancy Ack/RC No.RC.NO. 1433/A1/2009-1 dt.07/01/2022
3. Non Multi storeyed Building Inspection Committee Report.,  
Ack. No. 422530002021, dt. 07/01/2022

\*\*\*\*\*

1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of **SREENIDHI INTERNATIONAL SCHOOL (ACADEMIC BLOCK-2),SY.NO. 22,23,25 & 26, WATER PIPE LINE ROAD, AZIZNAGAR VILLAGE, MOINABAD MANDAL, RANGA REDDY DISTRICT. /-Aziznagar/Moinabad/Rangareddy**

2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with **1 Ground, 1 Floors**, with a height of **6.00** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy .

3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with **1 Ground, 1 Floors**, with a height of **6.00** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy

4) Open Spaces:The builder provided the following open spaces all around the building.

Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
a 1	North	6.00	6.00
2	South	6.00	6.00
3	East	6.00	6.00
4	West	6.00	6.00
b Sl. No	Gate Width As per Occupancy NOC	as per Noc occupancy	provided now
1	Entry gate width	4.50	7.0
2	Entry Gate Head Clearance	5.00	5.0
3	Exit Gate Width	4.50	7.0
4	Exit Gate Head Clearance	5.00	5.00

5) Travel Distance

For Sreenidhi International School

*Ambilam*

*meha*

Correspondent



Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point ( Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	29.95	29.95
2	The Dead end of the corridor length in exit access. ( 6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00	6.00

6) Stair Cases (As per Occupancy NOC) :

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
1	Internal staircases	1.50	1	Ground	1st Floor
2	External staircases	1.50	1	Ground	1st Floor

7) Means of Escape Floor Wise Details :

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per Occupancy NOC	Means escape available now
1	Ground	835.85	EDUCATIONAL B-1 Schools up to senior secondary level	209.00	4.18	8.00
2	1st Floor	473.00	EDUCATIONAL B-1 Schools up to senior secondary level	118.00	2.36	3.00

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Sl.no	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Electronic Fire Alarm System	Automatic detection and alarm system
1	Ground	5.00	1.00	0.00	0.00	0.00
2	1st Floor	3.00	1.00	0.00	0.00	0.00

10) Fire Fighting Installations As per Occupancy NOC :

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	8	8
First Aid Hose Reel	2	2
Terrace Tank over Respective Tower Terrace in Litres	10000	10000
Pump Capacity in LPM at the Terrace Tank Level with Minimum Pressure of 3.5 kg/cm <sup>2</sup>	450	450

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measures and there is no deficiencies.

12. Remarks :

Based on the Recommendation of the Inspection Committee, the issuance of Renewal of NOC for Occupancy was approved.

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with **SREENIDHI INTERNATIONAL SCHOOL (ACADEMIC BLOCK-2),SY.NO. 22,23,25 & 26, WATER PIPE LINE ROAD, AZIZNAGAR VILLAGE, MOINABAD MANDAL, RANGA REDDY DISTRICT. /-**

**Aziznagar/Moinabad/Rangareddy**

with a height of **6.00** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy subject to the following conditions

Sl No	Builder and Management Body	Occupant	Management Body and fire and security personnel
1	-a) All the fire protection	All the escape/exit routes shall not be kept locked/blocked or	All the occupants must know the correct method of operation of the fire fighting

	arrangements shall be maintained in good condition as seen during inspection. -b) Do's and Don'ts in case of fire shall be prominently displayed in entire building	encroached	systems installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for Five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely,  
District fire officer,  
Rangareddy Division.

Copies to:

- i) The Management
- ii) Non Multi storeyed Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"

*Amphibian*

For Sreenidhi International School

*mehle*

Correspondent



**GOVERNMENT OF TELANGANA**  
**STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**

**From:**  
The Multi Storeyed Building  
Inspection Committee,  
State Disaster Response & Fire Services,  
Ranga Reddy Division.

**To:**  
The Divisional Fire Officer,  
Ranga reddy dist.

**Rc. No. 42254/Online/MSB/RR/2021, Dated: 02-12-2021**

Sir,

**Sub :** Telangana State Disaster Response and Fire Services Department - Ranga Reddy Division -Renewal of No Objection Certificate to the SREENIDHI INTERNATIONAL SCHOOL (Kalabhavan) ,SY.NO. 22,23,25 & 26, WATER PIPE LINE ROAD, AZIZNAGAR VILLAGE, MOINABAD MANDAL, RANGA REDDY DISTRICT- Joint Inspection Report - Submitted - Regarding.

**Ref :** Online Application with Acknowledgement No. 422540002021.

\* \* \* \* \*

It is submitted that vide reference cited, the Management of SREENIDHI INTERNATIONAL SCHOOL (Kalabhavan BLOCK) ,SY.NO. 22,23,25 & 26, WATER PIPE LINE ROAD, AZIZNAGAR VILLAGE, MOINABAD MANDAL, RANGA REDDY DISTRICT has submitted application in online for Renewal of No Objection Certificate to their Building with Ground Floor + First Floor with a height of 5.40 meters .

2) The inspection committee has inspected the premises and found that the buiding does not come under the purview of Section 13 of Telangana fire Service act.

3) Hence, it is Not Recommended by the Inspection Committee for issuance of NOC to the above building.

Submitted for favour of kind perusal and necessary action.

Yours faithfully,

  
Station Fire Officer,  
Chevella

  
Asst. District Fire Officer,  
Ranga Reddy Dist.



For Sreenidhi International School

  
Correspondent

**GOVERNMENT OF TELANGANA**  
**STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**

**From:**  
The Multi Storeyed Building  
Inspection Committee,  
State Disaster Response & Fire Services,  
Ranga Reddy Division.

**To:**  
The Divisional Fire Officer,  
Ranga reddy dist.

**Rc. No. 42252/Online/MSB/RR/2021, Dated: 02-12-2021**

Sir,

**Sub :** Telangana State Disaster Response and Fire Services Department - Ranga Reddy Division -Renewal of No Objection Certificate to the SREENIDHI INTERNATIONAL SCHOOL (Administrative Block) ,SY.NO. 22,23,25 & 26, WATER PIPE LINE ROAD, AZIZNAGAR VILLAGE, MOINABAD MANDAL, RANGA REDDY DISTRICT- Joint Inspection Report - Submitted - Regarding.

**Ref :** Online Application with Acknowledgement No. 422520002021.


\* \* \* \* \*

It is submitted that vide reference cited, the Management of SREENIDHI INTERNATIONAL SCHOOL (Administrative B BLOCK) ,SY.NO. 22,23,25 & 26, WATER PIPE LINE ROAD, AZIZNAGAR VILLAGE, MOINABAD MANDAL, RANGA REDDY DISTRICT has submitted application in online for Renewal of No Objection Certificate to their Building with Ground Floor + Mezannine Floor with a height of 4.60 meters .

- 2) The inspection committee has inspected the premises and found that the building does not come under the purview of Section 13 of Telangana fire Service act.
- 3) Hence, it is Not Recommended by the Inspection Committee for issuance of NOC to the above building.

Submitted for favour of kind perusal and necessary action.

  
Station Fire Officer,  
Chevella

Yours faithfully,  
  
Asst. District Fire Officer,  
Ranga Reddy Dist.



For Sreenidhi International School  
  
Correspondent



**GOVERNMENT OF TELANGANA**  
**STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**

**From:**  
The Multi Storeyed Building  
Inspection Committee,  
State Disaster Response & Fire Services,  
Ranga Reddy Division.

**To:**  
The Divisional Fire Officer,  
Ranga Reddy dist.

**Rc. No. 42251/Online/MSB/RR/2021, Dated: 02-12-2021**

Sir,

**Sub :** Telangana State Disaster Response and Fire Services Department - Ranga Reddy Division -Renewal of No Objection Certificate to the SREENIDHI INTERNATIONAL SCHOOL (laboratory Block) ,SY.NO. 22,23,25 & 26, WATER PIPE LINE ROAD, AZIZNAGAR VILLAGE, MOINABAD MANDAL, RANGA REDDY DISTRICT- Joint Inspection Report - Submitted - Regarding.

**Ref :** Online Application with Acknowledgement No. 422510002021.

\* \* \* \* \*

It is submitted that vide reference cited, the Management of SREENIDHI INTERNATIONAL SCHOOL (Laboratory BLOCK) ,SY.NO. 22,23,25 & 26, WATER PIPE LINE ROAD, AZIZNAGAR VILLAGE, MOINABAD MANDAL, RANGA REDDY DISTRICT has submitted application in online for Renewal of No Objection Certificate to their Building with Ground Floor + First Floor with a height of 6.80 meters .

- 2) The inspection committee has inspected the premises and found that the building does not come under the purview of Section 13 of Telangana fire Service act.
- 3) Hence, it is Not Recommended by the Inspection Committee for issuance of NOC to the above building.

Submitted for favour of kind perusal and necessary action.

  
Station Fire Officer,  
Chevella

Yours faithfully,

  
Asst. District Fire Officer,  
Ranga Reddy Dist.



For Sreenidhi International School  
  
Correspondent

GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT

From:  
The Multi Storeyed Building  
Inspection Committee,  
State Disaster Response & Fire Services,  
Ranga Reddy Division.

To:  
The Divisional Fire Officer,  
Ranga reddy dist.

Re. No. 42248/Online/MSD/RR/2021, Dated: 02-12-2021

Sir,

Sub : Telangana State Disaster Response and Fire Services Department -  
Ranga Reddy Division -Renewal of No Objection Certificate to the  
SREENIDHI INTERNATIONAL SCHOOL (Sports BLOCK) ,SY.NO. 22,23,25 & 26, WATER  
PIPE LINE ROAD, AZIZNAGAR VILLAGE, MOINABAD MANDAL, RANGA REDDY  
DISTRICT- Joint Inspection Report - Submitted - Regarding.

Ref : Online Application with Acknowledgement No. 422480002021.

\* \* \* \* \*


It is submitted that vide reference cited, the Management of SREENIDHI  
INTERNATIONAL SCHOOL (Sports BLOCK) ,SY.NO. 22,23,25 & 26, WATER PIPE LINE ROAD,  
AZIZNAGAR VILLAGE, MOINABAD MANDAL, RANGA REDDY DISTRICT has submitted application  
in online for Renewal of No Objection Certificate to their sports Building with Ground  
Floor + First Floor with a height of 6.00 meters .

- 2) The inspection committee has inspected the premises and found that the  
building does not come under the purview of Section 13 of Telangana fire Service  
act.
- 3) Hence, it is Not Recommended by the Inspection Committee for issuance of f  
NOC to the above

Submitted for favour of kind perusal and necessary action.

  
Station Fire Officer,  
Chevella

Yours faithfully,

  
Asst. District Fire Officer,  
Ranga Reddy Dist.

Scanned with CamScanner

For Sreenidhi International School

*nehru*

Correspondent

*Antony*



**GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**

**From:**  
The Multi Storeyed Building  
Inspection Committee,  
State Disaster Response & Fire Services,  
Ranga Reddy Division.

**To:**  
The Divisional Fire Officer,  
Ranga reddy dist.

**Re. No. 42244/Online/MSB/RR/2021. Dated 02-12-2021**

Sir,

**Sub :** Telangana State Disaster Response and Fire Services Department -  
Ranga Reddy Division -Renewal of No Objection Certificate to the  
SREENIDHI INTERNATIONAL SCHOOL (HOSTEL BLOCK) ,SY.NO. 22,23,25 & 26, WATER  
PIPE LINE ROAD, AZIZNAGAR VILLAGE, MOINABAD MANDAL, RANGA REDDY  
DISTRICT- Joint Inspection Report - Submitted - Regarding.

**Ref :** Online Application with Acknowledgement No. 422440002021.

\* \* \* \* \*

It is submitted that vide reference cited, the Management of SREENIDHI  
INTERNATIONAL SCHOOL (HOSTEL BLOCK) ,SY.NO. 22,23,25 & 26, WATER PIPE LINE ROAD,  
AZIZNAGAR VILLAGE, MOINABAD MANDAL, RANGA REDDY DISTRICT has submitted application  
in online for Renewal of No Objection Certificate to their hostel Building with Ground  
Floor + First Floor with a height of 6.80 meters .


- 2) The inspection committee has inspected the premises and found that the  
building does not come under the purview of Section 13 of Telangana fire Service  
act.
- 3) Hence, it is Not Recommended by the Inspection Committee for issuance of f  
NOC to the above

Submitted for favour of kind perusal and necessary action.

  
02/12/2021

Station Fire Officer,  
Chevella

Yours faithfully,

  
LPM

Asst. District Fire Officer,  
Ranga Reddy Dist.

Scanned with CamScanner

For Sreenidhi International School

  
Correspondent